

CITY OF BIRMINGHAM - SUMMARY OF UNPERMITTED DISCHARGES

10/1/14 to 9/30/2015

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

| Date Reported | Location | ZIP | Ultimate Destination | Estimated Volume (gal) | Source | Cause | Weather Conditions | Action Taken |
|---------------|------------------------------------|-------|--|------------------------|-------------------|---|--------------------|--|
| 8-Oct-14 | 1137 Tin Mill Road | 35224 | Drainage Ditch | 149 | Manhole | Roots | No Rain | Blockage Removed |
| 21-Oct-14 | 1416 24th St SW | 35211 | Ground Absorbed | Not Determinable | Cleanout | Grease/ Debris/ Rags | No Rain | Blockage Removed |
| 22-Oct-14 | 301 Valley Crest Rd | 35215 | Ground Absorbed | 7749 | Cleanout/ Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 23-Oct-14 | 404 Old Farm Dr | 35215 | Ground Absorbed | 15 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 25-Oct-14 | 101 16th Ave W | 35204 | Storm Drain | Not Determinable | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 28-Oct-14 | 218 22nd St SW | 35211 | Ground Absorbed | 600 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 29-Oct-14 | 885 Twin Lake Dr | 35215 | Drainage Ditch | Not Determinable | Manhole | Grease/ Roots | No Rain | Blockage Removed |
| 4-Nov-14 | 490 Robert Jemison Rd | 35209 | Drainage Ditch | 3300 | Pipe | Gravity Main Break | No Rain | Line Repaired |
| 6-Nov-14 | 1901 6th Ave S | 35294 | Storm Drain | 486 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 8-Nov-14 | 948 Meadowbrook Dr | 35215 | Ground Absorbed | 139 | Manhole | Grease/ Rags/ Gravity Main Break | No Rain | Blockage Removed |
| 10-Nov-14 | 713 24th Ave NW | 35215 | Storm Drain | 115 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 10-Nov-14 | 7211 Division Ave | 35206 | Ground Absorbed | 28 | Pipe | Grease/ Roots/ Debris/ Rags/ Gravity Main Break | No Rain | Blockage Removed/ Line Will Be Video Inspected |
| 12-Nov-14 | 834 Elizabeth Dr | 35215 | Ground Absorbed | 2 | Manhole | Grease/ Roots | No Rain | Blockage Removed |
| 17-Nov-14 | 4600 Roscoe Ave | 35212 | Storm Drain | 2852 | Manhole | Grease/ Rags | Moderate Rain | Blockage Removed |
| 17-Nov-14 | 1116 Suncrest Lane | 35215 | Ground Absorbed | 4 | Cleanout | Debris/ Gravel | Moderate Rain | Blockage Removed |
| 17-Nov-14 | 901 46th St & Ave I | 35208 | Storm Drain | 1568 | Manhole | Grease/ Rags | Moderate Rain | Blockage Removed |
| 17-Nov-14 | Fulton Ave & 22nd St SW | 35211 | Ground Absorbed | Not Determinable | Manhole | Surcharge from Rain | Heavy Rain | Replaced Lid |
| 17-Nov-14 | St. Charles Ave & 21st St SW | 35211 | Drainage Ditch/ Feeder to Valley Creek | 3000 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 17-Nov-14 | 1625 & 1628 17th St SW | 35211 | Storm Drain/ Valley Creek | Not Determinable | Manhole | Surcharge from Rain | Heavy Rain | Not Overflowing Upon Crew Arrival |
| 23-Nov-14 | 5201 Beacon Dr | 35210 | Storm Drain/ Shades Creek | 735 | Manhole/ Cleanout | Grease/ Debris | Heavy Rain | Blockage Removed |
| 24-Nov-14 | 3600 Messer Airport Hwy | 35222 | Storm Drain | 1098 | Manhole | Debris/ Rags/ Rocks | Moderate Rain | Blockage Removed |
| 28-Nov-14 | 190 Pratt Hwy | 35214 | Storm Drain | 54 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 2-Dec-14 | 2211 South Park Dr SW | 35211 | Drainage Ditch/ Valley Creek | 10304 | Cleanout | Grease/ Rags | No Rain | Blockage Removed |
| 4-Dec-14 | 6716 Court N | 35228 | Drainage Ditch/ Valley Creek | 792 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 12-Dec-14 | 544 41st St N | 35222 | Storm Drain | 7878 | Manhole | Grease | No Rain | Blockage Removed |
| 12-Dec-14 | 1825 University Blvd | 35294 | Ground Absorbed/ Storm Drain/ Valley Creek | 14640 | Manhole | Debris | No Rain | Blockage Removed |
| 12-Dec-14 | 5721 Monte Sano Rd | 35228 | Ground Absorbed | 561 | Cleanout | Grease/ Rags | No Rain | Blockage Removed |
| 13-Dec-14 | 821 Sherwood Forest Dr | 35235 | Ground Absorbed | 972 | Cleanout | Grease/ Rags | No Rain | Blockage Removed |
| 15-Dec-14 | 544 41st St N | 35222 | Ground Absorbed | 3 | Manhole | Grease | No Rain | Blockage Removed |
| 15-Dec-14 | 300 16th St SW | 35211 | Ground Absorbed | 4 | Manhole | Roots | No Rain | Blockage Removed |
| 23-Dec-14 | 220 Navajo Trail NE | 35215 | Ground Absorbed/ Five Mile Creek | 48930 | Cleanout | Construction Damage | Moderate Rain | Line Repaired |
| 24-Dec-14 | 1766 Lincoln Ave SW | 35211 | Ground Absorbed/ Valley Creek | 2504 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 24-Dec-14 | 1624 & 1628 17th St SW | 35211 | Storm Drain/ Valley Creek | 4273 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 27-Dec-14 | 4363 Mountindale Rd | 35213 | Ground Absorbed | Not Determinable | Cleanout | Grease | No Rain | Blockage Removed |
| 28-Dec-14 | 1404 57th Place | 35228 | Ground Absorbed/ Storm Drain/ Valley Creek | 5573 | Cleanout/ Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 28-Dec-14 | 1624 & 1628 17th St SW | 35211 | Storm Drain/ Valley Creek | 816120 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 28-Dec-14 | 1617 & 1619 17th Pl SW | 35211 | Storm Drain/ Valley Creek | 24311 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 28-Dec-14 | St. Charles Ave & 21st St SW | 35211 | Valley Creek | 55154 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 28-Dec-14 | 2122 Fulton Ave SW | 35211 | Storm Drain/ Valley Creek | 1065 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 28-Dec-14 | 920 Fairdale Rd | 35221 | Feeder to Valley Creek | 83874 | Cleanout | Surcharge from Rain | Heavy Rain | Line Monitored |
| 28-Dec-14 | 4713 5th Ave | 35224 | Storm Drain/ Valley Creek | 8856 | Manhole | Grease/ Rags | Heavy Rain | Block Removed |
| 28-Dec-14 | 1767 Lincoln Ave SW | 35211 | Storm Drain/ Valley Creek | 8768 | Manhole | Grease/ Rags | Heavy Rain | Blockage Removed |
| 28-Dec-14 | 683 Tin Mill Road (Tin Mill Rd PS) | 35224 | Drainage Ditch/ Feeder to Valley Creek | Not Determinable | Pump Station | Surcharge from Rain/ P.S. Equipment | Heavy Rain | Pump Station Repaired |
| 29-Dec-14 | 1616 & 1625 Jefferson Ave SW | 35211 | Ground Absorbed/ Storm Drain/ Valley Creek | 5700 | Cleanout/ Manhole | Grease/ Debris | Light Rain | Blockage Removed |
| 29-Dec-14 | 208 10th Ave | 35204 | Ground Absorbed | 3611 | Cleanout | Grease/ Debris | Heavy Rain | Blockage Removed |
| 29-Dec-14 | Henry Crumpton & 20th St SW | 35211 | Drainage Ditch/ Feeder to Valley Creek | 337269 | Manhole | Surcharge from Rain | Light Rain | Pumped Down Siphon |
| 29-Dec-14 | 565 Ave G | 35214 | Storm Drain/ Village Creek | 11394 | Manhole | Rags | No Rain | Blockage Removed |
| 30-Dec-14 | 2801 Wilson Rd | 35211 | Storm Drain/ Valley Creek | 10100 | Manhole | Grease | No Rain | Blockage Removed |
| 4-Jan-15 | 3323 Ave H & 3401 Ave H | 35218 | Storm Drain/ Village Creek | 94006 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 4-Jan-15 | 3421 Ave F | 35218 | Storm Drain | 3135 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 4-Jan-15 | 3425 35th St | 35218 | Storm Drain | 5594 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 4-Jan-15 | 1272 16th St SW | 35211 | Storm Drain/ Feeder to Valley Creek | 23004 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 4-Jan-15 | 116 11th Ave SW | 35211 | Storm Drain/ Valley Creek | 515424 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 4-Jan-15 | 1616 & 1618 Jefferson Ave SW | 35211 | Ground Absorbed | Not Determinable | Cleanout | Surcharge from Rain | Heavy Rain | Line Monitored |
| 4-Jan-15 | 1015 31st St | 35218 | Storm Drain | 1422 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 4-Jan-15 | 2032 Henry Crumpton Dr SW | 35211 | Storm Drain/ Feeder to Valley Creek | 343290 | Manhole | Roots/ Debris/ Rags/ Surcharge from Rain | Heavy Rain | Blockage Removed/ Line Monitored |
| 4-Jan-15 | 920 Fairdale Rd | 35221 | Drainage Ditch/ Feeder to Valley Creek | 175424 | Cleanout | Surcharge from Rain | Heavy Rain | Line Monitored |
| 4-Jan-15 | 1625 & 1628 17th St SW | 35211 | Storm Drain/ Valley Creek | 6890037 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 4-Jan-15 | 1617 & 1619 17th Pl SW | 35211 | Storm Drain/ Valley Creek | 37805 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 4-Jan-15 | St Charles & 21st St SW | 35211 | Valley Creek | Not Determinable | Manhole | Surcharge from Rain | Heavy Rain | Not Overflowing Upon Crew Arrival |
| 4-Jan-15 | 2122 Fulton Ave SW | 35211 | Drainage Ditch/ Valley Creek | Not Determinable | Manhole | Surcharge from Rain | Heavy Rain | Not Overflowing Upon Crew Arrival |
| 5-Jan-15 | 7133 Oporto Madrid Blvd S | 35206 | Storm Drain | 177 | Manhole | Roots/ Debris | No Rain | Blockage Removed |

| | | | | | | | | |
|-----------|--|-------|-------------------------------------|------------------|-----------------------|------------------------------------|-------------------|---|
| 12-Jan-15 | 3020 33rd St SW | 35211 | Ground Absorbed | 35 | Manhole | Debris/ Rags | Light Rain | Blockage Removed |
| 19-Jan-15 | 1524 Five Mile Rd | 35215 | Ground Absorbed/ Drainage Ditch | 549 | Manhole | Roots/ Rags | No Rain | Blockage Removed |
| 26-Jan-15 | 4501 9th Ave N | 35212 | Ground Absorbed | 246 | Manhole | Grease/ Roots/ Rags/ Silt | Light Rain | Blockage Removed |
| 26-Jan-15 | 3690 Montclair Rd | 35213 | Ground Absorbed | Not Determinable | Pipe | Construction Damage | No Rain | Project Planned to Replace/ Repair Line |
| 27-Jan-15 | 2211 South Park Dr | 35211 | Ground Absorbed | 2590 | Cleanout | Grease | No Rain | Blockage Removed |
| 29-Jan-15 | 514 Park St & 524 Baker Dr | 35213 | Storm Drain | 868 | Cleanout/ Manhole | Grease/ Roots | No Rain | Blockage Removed |
| 2-Feb-15 | 345 Robison Dr | 35215 | Ground Absorbed | 2 | Cleanout | Roots/ Gravity Main Break/ Rocks | No Rain | Blockage Removed/ Line Repaired |
| 3-Feb-15 | 809 79th St S | 35206 | Ground Absorbed | 8 | Manhole | Grease/ Debris | No Rain | Blockage Removed |
| 3-Feb-15 | 2321 1st St S | 35205 | Drainage Ditch | 80 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 7-Feb-15 | 2331 Bessemer Rd | 35208 | Storm Drain | 3726 | Manhole | Rags | No Rain | Blockage Removed |
| 9-Feb-15 | 900 44th Pl N | 35212 | Ground Absorbed | 90 | Manhole | Grease | No Rain | Blockage Removed |
| 9-Feb-15 | 2501 3rd Ave S | 35233 | Storm Drain | 129 | Manhole | Debris | No Rain | Blockage Removed/ TV Inspection Scheduled |
| 16-Feb-15 | 4100 9th Ave | 35224 | Ground Absorbed | 765 | Cleanout | Grease/ Rags | No Rain | Blockage Removed |
| 20-Feb-15 | 849 47th Pl N | 35212 | Ground Absorbed | Not Determinable | Hole in Service Line | Grease/ Rags | No Rain | Blockage Removed |
| 22-Feb-15 | 6716 Court N | 35228 | Drainage Ditch | 2025 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 23-Feb-15 | 1625 17th St SW | 35211 | Storm Drain | 225280 | Manhole | Surcharge from Rain | Light Rain | Line Monitored |
| 23-Feb-15 | 1301 Vinesville Rd | 35208 | Ground Absorbed/ Valley Creek | 109230 | Manhole | Rocks | Moderate Rain | Blockage Removed |
| 23-Feb-15 | 1100 Crest Green Rd | 35212 | Storm Drain/ Village Creek | 10500 | Manhole | Gravity Main Break | Moderate Rain | Line Repaired/ Bypass pump setup |
| 25-Feb-15 | 3160 30th Cr N | 35207 | Storm Drain/ Village Creek | 84 | Manhole | Grease | No Rain | Blockage Removed |
| 26-Feb-15 | 101 Summit Blvd | 35243 | Storm Drain | 69 | Manhole | Grease | No Rain | Blockage Removed |
| 28-Feb-15 | 5700 Sunrise Pl | 35210 | Drainage Ditch | 540 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 2-Mar-15 | 5804 Oporto Madrid Blvd | 35210 | Ground Absorbed | 3480 | Cleanout | Grease/ Rags | No Rain | Blockage Removed |
| 4-Mar-15 | 933 Rockford Rd | 35222 | Ground Absorbed | 1744 | Manhole | Grease/ Roots/ Debris | No Rain | Blockage Removed |
| 4-Mar-15 | 4005 39th Court N | 35217 | Ground Absorbed | Not Determinable | Cleanout | Service Line Was Not Connected | No Rain | Service Reinstated |
| 7-Mar-15 | 6625 6th Court S | 35212 | Storm Drain | 25620 | Manhole | Grease | No Rain | Blockage Removed |
| 9-Mar-15 | 4713 5th Ave | 35224 | Storm Drain | 165 | Manhole | Grease/ Roots/ Rags | Light Rain | Blockage Removed |
| 17-Mar-15 | 8932 Glendale Dr | 35206 | Ground Absorbed | 23 | Manhole | Gravity Main Break/ Collapsed Pipe | No Rain | Blockage Removed |
| 17-Mar-15 | 6144 Owen St | 35202 | Storm Drain | 62 | Manhole | Grease/ Debris | No Rain | Blockage Removed |
| 18-Mar-15 | 3444 33rd Court N | 35207 | Ground Absorbed | 32 | Manhole | Grease/ Roots/ Debris/ Rocks | No Rain | Blockage Removed |
| 23-Mar-15 | 776 80th Pl S | 35206 | Storm Drain | 54 | Manhole | Construction Damage | No Rain | Line Repaired |
| 25-Mar-15 | 475 Valley Crest Dr | 35215 | Ground Absorbed | 5394 | Cleanout | Grease | No Rain | Blockage Removed |
| 25-Mar-15 | 3314 Clairmont Ave S | 35222 | Storm Drain | 4180 | Pipe | Gravity Main Break | No Rain | Line Repaired |
| 28-Mar-15 | 1115 Suncrest Lane | 35215 | Storm Drain | Not Determinable | Pipe | Gravity Main Break | No Rain | Bypass Pump Setup/ Line Repaired |
| 6-Apr-15 | 929 Five Mile Rd | 35215 | Ground Absorbed | 1520 | Manhole | Grease/ Rags | Light Rain | Blockage Removed |
| 9-Apr-15 | 537 Carolyn Court | 35206 | Ground Absorbed | 113 | Manhole | Roots/ Rags | No Rain | Blockage Removed |
| 9-Apr-15 | 2525 9th Cr S | 35205 | Ground Absorbed | 24 | Cleanout | Grease | No Rain | Blockage Removed |
| 14-Apr-15 | 1511 Crestwood Blvd | 35213 | Ground Absorbed | 60 | Manhole | Grease/ Roots/ Rags | No Rain | Blockage Removed |
| 17-Apr-15 | 1617 17th Pl SW | 35211 | Storm Drain/ Feeder to Valley Creek | 127604 | Manhole | Surcharge from Rain | Line Monitored | Line Monitored |
| 17-Apr-15 | 1625 & 1628 17st St SW | 35211 | Storm Drain/ Feeder to Valley Creek | 1972290 | Manhole | Surcharge from Rain | Light/ Heavy Rain | Line Monitored |
| 17-Apr-15 | 4150 Lewisburg Rd (Lewisburg No. 2 PS) | 35207 | Feeder to Village Creek | 3925 | Manhole | P.S. Equipment Failure | Heavy Rain | Pump Station Repaired |
| 17-Apr-15 | 5401 8th Ave (Wylam PS) | 35244 | Feeder to Valley Creek | 776 | Pump Station | P.S. Equipment Failure | Heavy Rain | Pump Station Repaired |
| 21-Apr-15 | 2612 Lane Park Rd | 35223 | Storm Drain/ Watkins Branch | Not Determinable | Manhole | Grease/ Rags | No Rain | Not Overflowing Upon Crew Arrival |
| 22-Apr-15 | 3411 Mary Taylor Rd | 35235 | Drainage Ditch | 9828 | Manhole | Debris | No Rain | Blockage Removed |
| 27-Apr-15 | 5601 10th Ave S | 35222 | Storm Drain | 875 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 3-May-15 | 1517 19th St SW | 35211 | Storm Drain | 1675 | Manhole | Bypass Pump Failure | No Rain | Blockage Removed |
| 4-May-15 | 439 Horner Dr | 35206 | Ground Absorbed | 89 | Pipe | Gravity Main Break | No Rain | Project Planned to Replace/ Repair Line |
| 5-May-15 | 1701 36th St N | 35234 | Drainage Ditch | 1386 | Manhole | Grease/ Debris | No Rain | Blockage Removed |
| 8-May-15 | 3040 44th Ave N | 35207 | Storm Drain | 534 | Cleanout | Grease/ Debris/ Rags | No Rain | Blockage Removed |
| 13-May-15 | 2130 5th Ave N | 35203 | Storm Drain | 201 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 19-May-15 | 1909 Cleburn Ave SW | 35211 | Ground Absorbed | 300 | Bypass Discharge Hose | Broken Bypass Hose | No Rain | Hose Was Repaired |
| 20-May-15 | 2450 Golden Pines Ln SW | 35211 | Storm Drain | Not Determinable | Manhole | Rags | No Rain | Blockage Removed |
| 31-May-15 | 209 Cathy Lane | 35215 | Storm Drain | 80 | Manhole | Grease/ Debris | No Rain | Blockage Removed |
| 1-Jun-15 | 3960 Montclair Rd | 35213 | Storm Drain | 53 | Manhole | Grease/ Roots/ Rags | Light Rain | Blockage Removed |
| 10-Jun-15 | 1830 10th Court S | 35205 | Storm Drain | 222 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 16-Jun-15 | 100 West Oxmoor Rd | 35209 | Storm Drain | 3510 | Manhole | Debris/ Rags | No Rain | Blockage Removed |
| 17-Jun-15 | 2917 Tempest Dr SW | 35211 | Ground Absorbed | 2 | Manhole | Grease/ Debris/ Rags | No Rain | Blockage Removed |
| 22-Jun-15 | 4921 Terrace R | 35208 | Ground Absorbed | Not Determinable | Pipe | Roots/ Debris/ Hole in Pipe | No Rain | Blockage Removed |
| 24-Jun-15 | 200 2nd Ave SW | 35211 | Storm Drain | 1116 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 27-Jun-15 | 4201 Ave T | 35208 | Storm Drain | 144 | Manhole | Grease/ Rags | Light Rain | Blockage Removed |
| 4-Jul-15 | 321 & 325 17th Ave SW | 35211 | Storm Drain/ Valley Creek | 55284 | Manhole/ Cleanout | Grease/ Debris | Heavy Rain | Blockage Removed |
| 4-Jul-15 | 2119 Fulton Ave SW | 35211 | Storm Drain/ Valley Creek | 14775 | Manhole | Surcharge from Rain | Heavy Rain | Line Monitored |
| 4-Jul-15 | 530 21st St SW | 35211 | Valley Creek | 46305 | Manhole | Surcharge from Rain | Heavy Rain | Surcharge Stopped/ Line Monitored |
| 4-Jul-15 | 1625 & 1628 17th St SW | 35211 | Storm Drain/ Valley Creek | Not Determinable | Manhole | Surcharge from Rain | Heavy Rain | Surcharge Had Stopped |
| 30-Jul-15 | 4001 East Lake Blvd | 35212 | Drainage Ditch | 337 | Pipe | Force Main Break | No Rain | Line Repaired |
| 3-Aug-15 | 423 Valley Lake Dr | 35206 | Ground Absorbed | 74 | Manhole | Grease/ Roots | No Rain | Blockage Removed |
| 4-Aug-15 | 4425 5th Ave S | 35222 | Ground Absorbed | 14 | Manhole | Grease/ Roots/ Rags | No Rain | Blockage Removed |
| 4-Aug-15 | 1404 19th St SW | 35211 | Storm Drain | 150 | Bypass Container | Bypass Container | No Rain | Cleaned Area |
| 12-Aug-15 | 1300 Crest Green Rd | 35212 | Storm Drain | 59 | Manhole | Grease/ Roots/ Rags | No Rain | Blockage Removed |
| 22-Aug-15 | 2901 Carlisle Rd | 35213 | Ground Absorbed | 7 | Pipe | Grease/ Debris | No Rain | Blockage Removed |

| | | | | | | | | |
|-----------|--------------------------------|-------|----------------------|------------------|----------|--|---------|---|
| 25-Aug-15 | 400 10th Crt N | 35204 | Ultimate Destination | 22440 | Manhole | Grease/ Roots/ Rags/ Pieces of Broken Pipe | No Rain | Blockage Removed |
| 27-Aug-15 | 844 Gas Light Trail | 35209 | Ground Absorbed | 5 | Pipe | Grease/ Rags | No Rain | Blockage Removed |
| 2-Sep-15 | 26 Pratt Hwy | 35214 | Storm Drain | 369 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 3-Sep-15 | 1425 Brighton Rd | 35228 | Ground Absorbed | 1 | Cleanout | Roots/ Gravity Main Break | No Rain | Blockage Removed/ Project Planned to Replace/ Repair Line |
| 4-Sep-15 | 2700 Arlington Ave S | 35205 | Storm Drain | 30140 | Pipe | Gravity Main Break | No Rain | Line Repaired |
| 4-Sep-15 | 4330 42rd Ave N | 35217 | Ground Absorbed | 1750 | Cleanout | Roots/ Rags | No Rain | Blockage Removed |
| 8-Sep-15 | 1624 Bradford St | 35214 | Ground Absorbed | 3038 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 14-Sep-15 | 17 Quebec Dr | 35224 | Ground Absorbed | 78 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 16-Sep-15 | 2 Watertown Circle | 35235 | Ground Absorbed | Not Determinable | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 16-Sep-15 | 1806 24th St SW | 35211 | Ground Absorbed | 3 | Pipe | Grease/ Rags | No Rain | Blockage Removed |
| 22-Sep-15 | 4325 Richard Arrington Jr Blvd | 35212 | Storm Drain | 48 | Manhole | Grease/ Rags | No Rain | Blockage Removed |
| 29-Sep-15 | 1000 4th Ter W | 35204 | Drainage Ditch | 183 | Manhole | Grease/ Debris | No Rain | Blockage Removed |