

November 3, 2009

ADDENDUM #1

On October 19, 2009 the City of Birmingham invited bids for Commercial HVAC Variable Frequency Drives, Invitation to Bid #09-53; said bid to be opened 2:00 p.m. November 20, 2009.

PLEASE NOTE:

- (1) Enclosed are specifications for 15 and 25 HP ABB Variable Frequency Drives. Drives are to be ABB or equal, however, cabinet size **MUST** match dimensions given. These items have been added to the corrected bid form.
- (2) A corrected bid form is enclosed.
- (3) Bid opening remains as scheduled; 2:00 p.m. November 20, 2009.

William E. Caffee
Assistant Purchasing Agent
City of Birmingham, AL

	Bidder Complies	
	Yes	No
15 HP ABB Variable Frequency Drive		
Three contactor Bypass	_____	_____
NEMA 1 Enclosure	_____	_____
Cabinet 54" H x 9" D x 5" W	_____	_____
Main Disconnect	_____	_____
Drive Fuses	_____	_____
Factory Start up	_____	_____
<u>460 volt 3 phase 60 Hz</u>	_____	_____
36 Month Parts and Labor Warranty	_____	_____
Compatible to Johnson Controls Metasys system	_____	_____
24/7 On Call Parts Availability	_____	_____
25 HP ABB Variable Frequency Drive		
Three contactor Bypass	_____	_____
NEMA 1 Enclosure	_____	_____
Cabinet 54" H x 9" D x 12" W	_____	_____
Main Disconnect	_____	_____
Drive Fuses	_____	_____
Factory Start up	_____	_____
<u>460 volt 3 phase 60 Hz</u>	_____	_____
36 Month Parts and Labor Warranty	_____	_____
Compatible to Johnson Controls Metasys system	_____	_____
24/7 On Call Parts Availability	_____	_____

Corrected Bid Form

W.E. Caffee
 Assistant Purchasing Agent
 Birmingham, Alabama

Submitted below is my firm bid for Commercial Variable Frequency Drives for the City of Birmingham, in accordance with your invitation to bid and specifications dated October 19, 2009. Prices are f.o.b. Birmingham, Alabama delivered and I am bidding in accordance with specifications except as listed below.

Approx Qty	Description	Make/Model	Unit Price	Extended Total
1	Commercial 5 HP Variable Frequency Drive		\$	\$
2	Commercial 7.5 HP Variable Frequency Drive		\$	\$
1	Commercial 10 HP Variable Frequency Drive		\$	\$
2	Commercial 20 HP Variable Frequency Drive		\$	\$
1	Commercial 40 HP Variable Frequency Drive		\$	\$
1	Commercial 7.5 HP Variable Frequency Drive 460v		\$	\$
2	Commercial 10 HP Variable Frequency Drive 460v		\$	\$
1	Commercial 15 HP ABB Variable Frequency Drive 460v		\$	\$
2	Commercial 25 HP ABB Variable Frequency Drive 460v		\$	\$
			GRAND TOTAL	\$